

**HEATING, VENTILATION AND AIR CONDITIONING (HVAC) – CONTROL****ADAPTIVE PHOTONIC CONTROL FOR HVAC FAN MOTORS****Measure Description**

This measure covers the installation of adaptive photonic control systems applied to HVAC fan motors. Adaptive photonic control involves integration with an HVAC system's motors including PTACs, PTHPs, mini-splits, central air units and furnace distribution system supply fans. It enables adaptive speed control for single-speed AC fan motors using sensors by continuously adapting to end-user requirements. The controller uses photonic (opto-electronic) transducers and graphical apertures that are integrated into intelligent, signal and vector processors enabling their use as analog power controllers<sup>1123, 1124</sup>. It provides an adaptive airflow solution by tracking air temperature and optimizing operation based on climate conditions. Savings accrue not only from the reduction of fan speed to match thermal delivery rates, but also through better air mixing in the space and more effective heat transfer on the coils when the system is in operation. By adjusting airflow to improve heat transfer, the controller improves whole system operating efficiency and significantly reduces compressor run times.

This measure is only applicable to adaptive photonic control integrated into single-speed AC induction fan motors rated up to 5 horsepower (HP) that do not have speed variability restriction (e.g., via centrifugal speed switch).<sup>1125, 1126</sup> Savings estimated per this methodology may be claimed in retrofit applications as well as in new construction applications where electronically commutated (EC) motors are not otherwise required by federal, state, local or municipal codes or standards.

**Method for Calculating Annual Energy and Peak Coincident Demand Savings***Annual Electric Energy Savings*

$$\Delta kWh = \Delta kWh_{cooling} + \Delta kWh_{heating} + \Delta kWh_{fan}$$

$$\Delta kWh_{cooling} = units \times \frac{(W_{cooling} \times ESF)}{1,000} \times LF \times hrs_{cooling}$$

$$\Delta kWh_{heating} = units \times \frac{(W_{heating} \times ESF)}{1,000} \times LF \times hrs_{heating}$$

$$\Delta kWh_{fan} = units \times \frac{(W_{blowerfan} \times ESF)}{1,000} \times LF \times hrs_{fan}$$

Note:  $\Delta kWh_{fan}$  is only applicable if fan is set to on position during occupancy

<sup>1123</sup> IEEE Transactions on Industrial Electronics, 'A novel switched reluctance motor drive with optical graphical programming technology', 2000.

<sup>1124</sup> ACHR News, Fan Coil Units Get VSD, 2005

<sup>1125</sup> San Diego Gas & Electric, Work Paper WPSDGENRHC1051, Revision 1, Sept 2016

<sup>1126</sup> Comfort-Plus Drive™, Variable Speed Drive for Fan Coil Units, 2005

*Summer Peak Coincident Demand Savings*

$$\Delta kW = \text{units} \times \frac{(W_{cooling} \times ESF)}{1,000} \times LF \times CF$$

*Annual Fossil Fuel Energy Savings*

$$\Delta MMBtu = \text{units} \times \frac{(kBtu/h_{in} \times ESF)}{1,000} \times LF \times hrs_{heating}$$

**where:**

$$W_{cooling} = W_{evaporator} + W_{compressor} + W_{condenser}$$

$$W_{heating} = W_{evaporator} + W_{ElecHeat}$$

$$W_{evaporator} = V_{evaporator} \times A_{evaporator} \times PF$$

$$W_{compressor} = V_{compressor} \times A_{compressor} \times PF$$

$$W_{condenser} = V_{condenser} \times A_{condenser} \times PF$$

$$hrs_{fan} = hrs - (hrs_{cooling} + hrs_{heating})$$

**where:**

- $\Delta kWh$  = Annual electric energy savings
- $\Delta kW$  = Peak coincident demand electric savings
- $\Delta MMBtu$  = Annual fossil fuel energy savings
- $\Delta kWh_{cooling}$  = Annual electric energy savings in cooling mode
- $\Delta kWh_{heating}$  = Annual electric energy savings in heating mode
- $\Delta kWh_{fan}$  = Annual electric energy savings in fan only mode
- units = Number of measures installed under the program
- $W_{cooling}$  = Retrofitted system peak wattage in cooling mode
- $W_{heating}$  = Retrofitted system peak wattage in heating mode
- $W_{evaporator}$  = Retrofitted system evaporator wattage, based on nameplate specifications
- $W_{compressor}$  = Retrofitted system compressor wattage, based on nameplate specifications
- $W_{condenser}$  = Retrofitted system condenser wattage, based on nameplate specifications
- $W_{blowerfan}$  = Retrofitted system blower fan wattage, based on nameplate specifications
- $W_{ElecHeat}$  = Retrofitted system electric resistance heating element wattage, based on nameplate specifications, where applicable
- $V_{evaporator}$  = Retrofitted system evaporator voltage
- $V_{compressor}$  = Retrofitted system compressor voltage
- $V_{condenser}$  = Retrofitted system condenser voltage
- $A_{evaporator}$  = Retrofitted system evaporator amps
- $A_{compressor}$  = Retrofitted system compressor amps

|                                    |   |
|------------------------------------|---|
| $A_{\text{condenser}}$             | = Retrofitted system condenser amps                           |
| PF                                 | = Power factor  |
| $\text{kBtu}/\text{h}_{\text{in}}$ | = Retrofitted system space heating input fuel rating (kBtu/h) |
| ESF                                | = Energy savings factor                                       |
| LF                                 | = Motor load factor   |
| $\text{hrs}_{\text{cooling}}$      | = Retrofitted system annual operating hours in cooling mode   |
| $\text{hrs}_{\text{heating}}$      | = Retrofitted system annual operating hours in heating mode   |
| $\text{hrs}_{\text{fan}}$          | = Retrofitted system annual operating hours in fan only mode  |
| hrs                                | = Retrofitted system annual operating hours                   |
| CF                                 | = Coincidence factor  |
| 1,000                              | = Conversion factor, one kW equals 1,000 watts                |

### Summary of Variables and Data Sources

| Variable                           | Value | Notes   |
|------------------------------------|-------|---|
| $W_{\text{ElecHeat}}$              |       | From application.   |
| $W_{\text{blowerfan}}$             |       | From application.   |
| $V_{\text{evaporator}}$            |       | From application.   |
| $V_{\text{compressor}}$            |       | From application.   |
| $V_{\text{condenser}}$             |       | From application.   |
| $A_{\text{evaporator}}$            |       | From application.   |
| $A_{\text{compressor}}$            |       | From application.   |
| $A_{\text{condenser}}$             |       | From application.   |
| PF                                 | 0.85  | From Standard Handbook of Electrical Engineers <sup>1127</sup> and the Engineering Toolbox. <sup>1128</sup> |
| $\text{kBtu}/\text{h}_{\text{in}}$ |       | From application.   |
| ESF                                | 0.30  | Average of multiple validation tests. <sup>1129</sup>   |
| LF                                 | 0.9   | Assumed value to reflect that motors do not typically run at 100% of rated power.                           |
| $\text{hrs}_{\text{cooling}}$      |       | From application. If unknown, see Operating Hours section below.  |
| $\text{hrs}_{\text{heating}}$      |       | From application. If unknown, see Operating Hours section below.  |
| hrs                                |       | From application. If unknown, see Operating Hours section below.  |
| CF                                 | 0.8   |   |

### Coincidence Factor (CF)

The prescribed value for the coincidence factor is 0.8.<sup>1130</sup>

<sup>1127</sup> Standard Handbook for Electrical Engineers (McGraw-Hill Handbooks), Donald G. Fink, ISBN 10: 0070220050 / ISBN 13: 9780070220058, Published by McGraw-Hill Publishing Co., 1999

<sup>1128</sup> Engineering Tool Box, Power Factors for Inductive Loads, [https://www.engineeringtoolbox.com/power-factor-electrical-motor-d\\_654.html](https://www.engineeringtoolbox.com/power-factor-electrical-motor-d_654.html)

<sup>1129</sup> Alectic, Adaptive Control Technologies, Validation Tests

<sup>1130</sup> No source specified – update pending availability and review of applicable references

**Baseline Efficiencies from which Savings are Calculated**

The baseline condition is a standard efficiency, single-speed AC induction motor in a direct-drive HVAC circulation (blower) fan application. Baseline wattage shall be derived from the nameplate rating of existing system components.

**Compliance Efficiency from which Incentives are Calculated**

The compliance condition is a single-speed AC induction motor with adaptive photonic control as described in the Measure Description section above in a direct-drive HVAC circulation (blower) fan application.

**Operating Hours**

Annual cooling mode, heating mode and total system operating hours shall be taken from application. If the operating hours are unknown, look up cooling and heating mode operating hours from [Appendix G](#) (i.e., cooling and heating equivalent load full hours shall be used as proxy values for annual cooling mode and annual heating mode hours, respectively). If the circulation fan is set to on during facility operation, look up total system operating hours by building type from the table below.

| Facility Type   | Hours (hrs/yr) | HVAC Int | Facility Type                   | Hours (hrs/yr) | HVAC Int  |
|---|----------------|----------|---------------------------------|----------------|-----------|
| Auto Related*   | 2,810          | AR       | Manufacturing Facility          | 2,857          | Ind       |
| Automotive / Transportation Service or Repair Facility (24/7) | 8,760          | AR       | Medical Offices                 | 3,748          | SOfc      |
| Bakery  | 2,854          | FS       | Motion Picture Theatre          | 1,954          | Asy       |
| Banks   | 3,748          | SOfc     | Multi-Family (Common Areas)     | 7,665          | MFL       |
| Church  | 1,955          | Rel      | Museum                          | 3,748          | Asy       |
| College – Cafeteria**   | 2,713          | FS       | Nursing Homes                   | 5,840          | MFL       |
| College – Classes   | 2,586          | CC       | Office (General Office Types)** | 3,013          | SOfc/LOfc |
| College - Dormitory   | 3,066          | Dorm     | Parking Garages                 | 4,368          | None      |
| Commercial Condos***  | 3,100          | SOfc     | Parking Garages (24/7)          | 7,717          | None      |
| Convenience Stores  | 6,376          | SRet     | Parking Lots                    | 4,100          | None      |
| Convention Center   | 1,954          | Asy      | Penitentiary                    | 5,477          | MFL       |
| Court House   | 3,748          | LOfc     | Performing Arts Theatre         | 2,586          | Asy       |
| Dining: Bar Lounge/Leisure                                    | 4,182          | FS       | Police / Fire Stations (24 Hr)  | 7,665          | Asy       |
| Dining: Cafeteria / Fast Food                                 | 6,456          | FF       | Post Office                     | 3,748          | SRet      |
| Dining: Family  | 4,182          | FS       | Pump Stations                   | 1,949          | Ind       |
| Entertainment   | 1,952          | Asy      | Refrigerated Warehouse          | 2,602          | RWH       |
| Exercise Center   | 5,836          | SRet     | Religious Building              | 1,955          | Rel       |
| Fast Food Restaurants   | 6,376          | FF       | Restaurants                     | 4,182          | FS        |

| Facility Type           | Hours (hrs/yr) | HVAC Int        | Facility Type                  | Hours (hrs/yr) | HVAC Int      |
|-------------------------|----------------|-----------------|--------------------------------|----------------|---------------|
| Fire Station (Unmanned) | 1,953          | Asy             | Retail                         | 3,463          | SRet/<br>LRet |
| Food Stores             | 4,055          | Gro             | School / University            | 2,187          | Univ          |
| Gymnasium               | 2,586          | Asy             | Schools (Jr./Sr. High)         | 2,187          | HS            |
| Hospitals               | 7,674          | Hosp            | Schools (Preschool/Elementary) | 2,187          | Sch           |
| Hospitals / Health Care | 7,666          | Hosp            | Schools (Technical/Vocational) | 2,187          | CC            |
| Industrial - 1 Shift    | 2,857          | Ind             | Small Services                 | 3,750          | SOfc          |
| Industrial - 2 Shift    | 4,730          | Ind             | Sports Arena                   | 1,954          | Asy           |
| Industrial - 3 Shift    | 6,631          | Ind             | Town Hall                      | 3,748          | Asy           |
| Laundromats             | 4,056          | SRet            | Transportation                 | 6,456          | Asy           |
| Library                 | 3,748          | LOfc            | Warehouse (Not Refrigerated)   | 2,602          | WH            |
| Light Manufacturers**   | 2,613          | Ind             | Waste Water Treatment Plant    | 6,631          | Ind           |
| Lodging (Hotels/Motels) | 3,064          | Hotel/<br>Motel | Workshop                       | 3,750          | Ind           |
| Mall Concourse          | 4,833          | LRet            |                                |                |               |

\* New car showrooms and Big Box retail stores with evening and/or weekend hours should use the Facility Type "Retail" for lighting operating hours.

\*\* Lighting operating hours data from the 2008 California DEER Update study

\*\*\* Lighting operating hours data for offices used

**Example Calculation** *(Not to be used as default)*

An adaptive photonic control system is installed on a central air conditioning and 150 kBtu/h gas heating system in a small office building. The system’s compressor is rated at 230 V and 28.2 amps, the condenser is rated at 230 V and 2.4 amps and the evaporator is rated at 230 V and 12 amps. The blower fan has a rated wattage of 2.25 kW. The system runs in cooling mode for approximately 600 hours per year, in heating mode for approximately 1,600 hours per year and in fan only mode for approximately 1,500 hours per year, for a total of 3,700 hours annually. Annual Electric Energy Savings, Summer Peak Coincident Demand Savings and Annual Fossil Fuel Energy Savings are calculated as below.

$$\Delta kWh = \Delta kWh_{cooling} + \Delta kWh_{heating} + \Delta kWh_{fan}$$

$$\Delta kWh_{cooling} = units \times \frac{(W_{cooling} \times ESF)}{1,000} \times LF \times hrs_{cooling}$$

$$\Delta kWh_{heating} = units \times \frac{(W_{heating} \times ESF)}{1,000} \times LF \times hrs_{heating}$$

$$\Delta kWh_{fan} = units \times \frac{(W_{blowerfan} \times ESF)}{1,000} \times LF \times hrs_{fan}$$

$$\Delta kW = \text{units} \times \frac{(W_{cooling} \times ESF)}{1,000} \times LF \times CF$$

$$\Delta MMBtu = \text{units} \times \frac{(kBtu/h_{in} \times ESF)}{1,000} \times LF \times hrs_{heating}$$

units = 1, from application

$$W_{cooling} = W_{evaporator} + W_{compressor} + W_{condensor} = 2,346 + 5,513 + 469 = 8,328 \text{ W}$$

$W_{cooling}$  equation from 'where' section

$$W_{evaporator} = V_{evaporator} \times A_{evaporator} \times PF = 230 \times 12 \times 0.85 = 2,346 \text{ W}$$

$W_{evaporator}$  equation from 'where' section

$V_{evaporator}$  from application

$A_{evaporator}$  from application

PF from Summary of Variables and Data Sources table

$$W_{compressor} = V_{compressor} \times A_{compressor} \times PF = 230 \times 28.2 \times 0.85 = 5,513 \text{ W}$$

$W_{compressor}$  equation from 'where' section

$V_{compressor}$  from application

$A_{compressor}$  from application

$$W_{condensor} = V_{condensor} \times A_{condensor} \times PF = 230 \times 2.4 \times 0.85 = 469 \text{ W}$$

$W_{condensor}$  equation from 'where' section

$V_{condensor}$  from application

$A_{condensor}$  from application

ESF = 0.3 from Summary of Variables and Data Sources table

LF = 0.9 from Summary of Variables and Data Sources table

hrs<sub>cooling</sub> = 600, from application

$W_{heating}$  = 0, from application

$W_{blowerfan}$  = 2,250, from application

$$hrs_{fan} = hrs - (hrs_{cooling} + hrs_{heating}) = 3,700 - (600 + 1,600) = 1,500$$

hrs from application

hrs<sub>heating</sub> from application

CF = 0.69, from Summary of Variables and Data Sources table

kBtu/h<sub>in</sub> = 150, from application

$$\Delta kWh_{cooling} = 1 \times \frac{(8,328 \times 0.3)}{1,000} \times 0.9 \times 600 = 1,349 \text{ kWh}$$

$$\Delta kWh_{fan} = 1 \times \frac{(2,250 \times 0.3)}{1,000} \times 0.9 \times 1,500 = 911 \text{ kWh}$$

$$\Delta kWh = 1,349 + 0 + 911 = 2,260 \text{ kWh}$$

$$\Delta kW = 1 \times \frac{(8,328 \times 0.3)}{1,000} \times 0.9 \times 0.69 = 1.55 \text{ kW}$$

$$\Delta MMBtu = 1 \times \frac{(150 \times 0.3)}{1,000} \times 0.9 \times 1,600 = 64.8 \text{ MMBtu}$$

### Effective Useful Life (EUL)

See [Appendix P](#).

### Ancillary Fossil Fuel Savings Impacts

HVAC circulation fans with adaptive photonic controlled AC motors generate less heat during operation, resulting in decreased cooling loads and increased heating loads. These effects are captured in the prescribed methodology detailed above. The HVAC interaction factors calculated from the prototypical building DOE-2 models as a function of the building and HVAC system type are shown in [Appendix D](#).

### Ancillary Electric Savings Impacts

HVAC circulation fan with adaptive photonic controlled AC motors generate less heat during operation, resulting in decreased cooling loads and increased heating loads. These effects are captured in the prescribed methodology detailed above. The HVAC interaction factors calculated from the prototypical building DOE-2 models as a function of the building and HVAC system type are shown in [Appendix D](#).

### References

1. A novel switched reluctance motor drive with optical graphical programming technology, Clarkson University, P. Pillay; Yaguang Liu; O.G. Durham, IEEE Transactions on Industrial Electronics (Volume: 47, Issue: 4, Aug 2000).  
Available from: <https://ieeexplore.ieee.org/document/857972>
2. Fan Coil Units Get VSD, The Air Conditioning, Heating, Refrigeration News, 2005  
Available from: <https://www.achrnews.com/articles/95898-fan-coil-units-get-vsd#:~:text=They%20are%20small%20air%2Dhandling,stacked%2C%20or%20installed%20horizontally%20overhead.>
3. Guest Room PTAC/PTHP Adaptive Climate Controller, San Diego Gas & Electric, Energy Efficiency Engineering, Work Paper WPSDGENRHC1051, Revision 1, Sept 2016.  
Available from: <http://www.deeresources.net/workpapers>
4. Comfort-Plus Drive™, Variable Speed Drive for Fan Coil Units, Carrier Corporation, 2005  
Available from: <https://dms.hvacpartners.com/docs/1003/Public/08/05-02-0501-01.pdf>
5. Standard Handbook for Electrical Engineers (McGraw-Hill Handbooks), Donald G. Fink, ISBN 10: 0070220050 / ISBN 13: 9780070220058, Published by McGraw-Hill Publishing Co., 1999
6. Engineering Tool Box, Power Factors for Inductive Loads  
Available from: [https://www.engineeringtoolbox.com/power-factor-electrical-motor-d\\_654.html](https://www.engineeringtoolbox.com/power-factor-electrical-motor-d_654.html)

7. Multiple Validation Tests of Adaptive Photonic Technology Controller at (1) ConEdison, (2) Environmental Test Laboratory, (3) EME Consulting Engineers (NYSERDA), (4) SUNY Oneonta, (5) Tim Garrison (Third Party), (6) McQuay Cooling Tests, (7) Purdue University Tests and (8) ConEdison Tests by ERS.

Available from: [https://efbb029c-a900-4301-9ab1-40fc00b9e54e.filesusr.com/ugd/9cd7aa\\_186d85d0a69b4da4b69f07ea0d03eeff.pdf?index=true](https://efbb029c-a900-4301-9ab1-40fc00b9e54e.filesusr.com/ugd/9cd7aa_186d85d0a69b4da4b69f07ea0d03eeff.pdf?index=true)

**Record of Revision**

| <b>Record of Revision Number</b> | <b>Issue Date</b> |
|----------------------------------|-------------------|
| 12-20-7                          | 12/31/2020        |
| 3-21-23                          | 4/9/2021          |
|                                  |                   |

[\*Return to Table of Contents\*](#)